

LESEN PENSIJILAN BARANGAN

Product Certification Licence



SIRIM

SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to

**ALAM-CON SDN. BHD.
PT 9125, TAMAN PERINDUSTRIAN TUNZEN
31300 KAMPUNG KEPAYANG
PERAK, MALAYSIA**

Lesen untuk menggunakan Tanda Pensijilan di atas barangan
a licence to use the Certification Mark on

AUTOCLAVED AERATED CONCRETE MASONRY UNITS (BLOCK)

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan
as complying with

**BS EN 771-4 : 2003
BS 476 : PART 22 : 1987**



Nur Fadhilah binti Muhammad
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

ALAM-CON SDN. BHD.



Trade Mark : ACON
Model : A3 (Tested to BS EN 771-4 : 2011) Nominal Net Dry Density: 590 kg/m³ Nominal Compressive Strength: 3 N/mm²
Rating : Four (4) hours; Integrity: 240 Minutes, Insulation: 240 Minutes
Type : Solid
Size : 600mm(l) x 100mm(w) x 200mm(h)
600mm(l) x 125mm(w) x 200mm(h)
600mm(l) x 150mm(w) x 200mm(h)
600mm(l) x 175mm(w) x 200mm(h)
600mm(l) x 200mm(w) x 200mm(h)

Test Report No.: 2021CB0085, 2021CB0086, 2017CB1226, 2017CB1225, 2017FE0582

Trade Mark : ACON
Model : A5 (Tested to BS EN 771-4 : 2011) Nominal Net Dry Density: 730 kg/m³ Nominal Compressive Strength: 5 N/mm²
Rating : Four (4) hours; Integrity: 240 Minutes, Insulation: 240 Minutes
The product has also been tested and passed Hose stream test in accordance with Standard ASTM E2226
Type : Solid
Size : 600mm(l) x 100mm(w) x 200mm(h)
600mm(l) x 125mm(w) x 200mm(h)
600mm(l) x 150mm(w) x 200mm(h)
600mm(l) x 175mm(w) x 200mm(h)
600mm(l) x 200mm(w) x 200mm(h)

Test Report No.: 2020CB0695, 2020CB0696, 2018CB0122, 2018CB0121, 2021FE0481

Trade Mark : ACON
Model : A7 (Tested to BS EN 771-4 : 2011) Nominal Net Dry Density: 760 kg/m³ Nominal Compressive Strength: 7 N/mm²
Rating : Four (4) hours; Integrity: 240 Minutes, Insulation: 240 Minutes
The product has also been tested and passed Hose stream test in accordance with Standard ASTM E2226
Type : Solid
Size : 600mm(l) x 100mm(w) x 200mm(h)
600mm(l) x 125mm(w) x 200mm(h)
600mm(l) x 150mm(w) x 200mm(h)
600mm(l) x 175mm(w) x 200mm(h)
600mm(l) x 200mm(w) x 200mm(h)

Test Report No.: 2021CB0218, 2021CB0217, 2021FE0101



No Lesen : **PC000414**

Licence No :

SCHEDULE

ALAM-CON SDN. BHD.



SIRIM

Factory Name and Location :
ALAM-CON SDN. BHD.
PT 9121-PT 9126
PT 23075 & PT23076
TAMAN PERINDUSTRIAN TUNGZEN
31200 KAMPUNG KEPAYANG
PERAK, MALAYSIA

End of page

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 410334-X)
1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 60-3-55446400
Faks : 60-3-55446466

<http://www.sirim.my>
<http://www.malaysian-certified.my>

Tarikh Mula Pensijilan : 20 November 2012

Certified Since

Sah Sehingga : 20 November 2022

Valid Until

Tarikh Dikeluarkan : 13 January 2022

Issue Date

No Siri : 070800

Serial No

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.